

REQUEST FOR INFORMATION		Please telefax this form to (216) 902-6277 or 6278
REQUESTOR SECTION	From: Faust Corporation	Date: August 25, 2008
	To: Contracting Officer Attn: <u>Laurie Walker</u> USCG Civil Engineering Unit Cleveland	
	1. Solicitation Number: HSCG83-08-B-3WT311	2. Location of Project: Lorain, OH
	3. Information Requested: <i>(Include Specification Section and/or Drawing Number and Page if inquiring about a discrepancy)</i> 1. Please review preservative treatment for piling and timber. (Section 02461, Paragraph 2.2 & Section 06100, Paragraph 2.1) a. Piling .60 pcf ? - Normally .80 pcf b. Timber CCA 2.5 pcf ? (Salt Water Spec.) - Normally .60 pcf - Should not be CCA for human contact.	
	Attachments:	Date Response Required: ASAP
	By: Ed Piotrowski	Title: Vice-President
	Requestor's FAX Number:	Requestor's Telephone Number:

CEU RESPONSE	To: <u>Lodge</u>	Date: <u>8/26/08</u>
	Response: 1a. 0.80pcf is acceptable for piling 1b. Marine lumber and timbers shall have a minimum of 0.60 pcf CCA preservative treatment in lieu of 2.5 pcf CCA treatment shown in specification. This is in accordance with Standard AWPA C3. CCA is acceptable for Marine Construction applications and shall remain a requirement of the contract.	
	<input type="checkbox"/> This information is a clarification of the solicitation and does not change the terms or conditions in any way. <input checked="" type="checkbox"/> This information is a proposed change to the solicitation. An amendment will be issued.	
	Contracting Officer: Laurie Walker, Contract Specialist	